

Site Evaluation Forms developed for the Energy Trust of Oregon are discussed, particularly the estimation of the effects of shading on PV system output. Preliminary results from monitoring of six PV systems in Oregon are also discussed. A systematic difference between measured data and PV Watts based modeled values has been found for low irradiance values.